

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-1130:132 Page 1 of 1

CATEGORY: Leakage Dampers

LISTEE: Honeywell, 1500 W. Dundee Rd., Arlington Heights IL 60004-1472
Contact: Bob Hodgson (847) 797-4403

DESIGN: Models D640SD2, D641SD2, D644SD2 and D645SD2. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, leakage rating and UL label.

APPROVAL: Listed as a Class II leakage-rated damper. Rating applies only when dampers are used with UL listed Honeywell damper actuators.

NOTE: Formerly 3225-1130:132

08-17-93



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 12, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager